



# TOI TE ORA PUBLIC HEALTH

Bay of Plenty + Lakes Districts

Toi Te Ora Public Health  
PO Box 2120  
TAURANGA 3140

26 October 2021

Tēnā koutou Rotorua Lakes Council

## **Report on Compliance with the Drinking-water Standards for New Zealand 2005 (Revised 2018) and duties under Health Act 1956 For Period: (01/07/20 – 30/06/21)**

An official assessment of the performance of (Rotorua lakes Council) as a “water supplier”, against the Health Act 1956, Part 2A, Drinking Water (the Act), and the Drinking-water Standards for New Zealand 2005 (Revised 2018) (DWSNZ) has been completed for the period 1<sup>st</sup> July 2020 – 30<sup>th</sup> June 2021. The assessment was undertaken by a Drinking Water Assessor (DWA) from Central North Island Drinking Water Assessor Unit (CNIDWAU) Tauranga Branch. The tables below show a summary of compliance for Treatment Plants and Distribution Zones with the DWSNZ, and compliance with the Health Act. Specific detail on compliance decisions are available in Drinking Water Online (DWO).

### Treatment Plants

<b>Treatment Plant name</b>	<b>Bacterial compliance</b>	<b>Protozoa compliance</b>	<b>Cyanotoxin compliance</b>	<b>Chemical compliance</b>	<b>Radiological compliance</b>	<b>Overall</b>
Deep Creek (TP02583)	√	√	√	√	N/A	√
Hamurana (TP00284)	√	√	√	√	N/A	√
Mamaku (TP00285)	√	√	N/A	√	√	√
Matipo (TP02995)	√	√	√	√	N/A	√
Reporoa (TP00278)	√	√	√	√	N/A	√
Rotoiti (TP00379)	√	√	√	√	N/A	√
Rotoma (TP00287)	√	√	√	√	N/A	√

Taniwha Springs (TP00289)	√	√	√	√	N/A	√
Utuhina (TP00288)	√	√	√	√	N/A	√
Whakarewarewa Forest Springs (TP00279)	√	√	√	√	N/A	√

Distribution Zones

Distribution Zone name	Bacterial compliance	Cyanotoxin compliance	Chemical compliance	Overall
Hamurana (HAM003HA)	√	N/A	√	√
Kaharoa (HAM003KA)	√	N/A	√	√
Mamaku Township (MAM001MA)	√	N/A	√	√
Ngongotaha Township (NGO01NG)	√	N/A	√	√
Okareka (ROT001OK)	√	N/A	√	√
Reporoa (REP001RE)	√	N/A	√	√
Rotoiti (ROT004RO)	√	N/A	√	√
Rotoma (ROT002RO)	√	N/A	√	√
Rotorua City (ROT003RO)	√	N/A	√	√
Rotorua Eastern Suburbs (ROT001RE)	√	N/A	√	√

Health Act

<b>Section of Health Act</b>	<b>Result</b>
Section 69S – Duty of suppliers in relation to the provision of drinking water	Met for all supplies.
Section 69U – Duty to take reasonable steps to contribute to protection of source of drinking water	Met for all supplies.
Section 69Y – Duty to monitor drinking-water	Met for all supplies.
Section 69Z – Duty to prepare and implement water safety plan Section 69ZB – Duration of plans Section 69ZC – Review and renewal of plans	Met for all supplies.
Section 69ZD – Duty to keep records and make them available	Met for all supplies.
Section 69ZE – Duty to investigate complaints	Met for all supplies.
Section 69ZF – Duty to take remedial actions	Met for all supplies.

Information in this report may be provided to the Ministry of Health at their request. With the exception of the Ministry of Health, this report shall not be reproduced without the approval of the CNIDWAU Tauranga Branch and Rotorua Lakes Council.

If you do not agree with the findings of this report a written appeal must be lodged with the Ministry of Health via, [notifydrinkingwater@health.govt.nz](mailto:notifydrinkingwater@health.govt.nz), within two months of receipt of this report.

Yours sincerely



Cameron Huxley  
Drinking Water Assessor

