

outside of the pool fence).

900mm minimum between horizontal rails.

Gaps under fence no larger than 100mm.

10

BC No:

## Inspection Checklist: Swimming Pools

Contact on site (Name, licence no. – RBW, company & position)

Ref: IC 18
Ver: 4
Issued: 1 July 2010
Doc No: IT-639958
Page 1 of 2

Date	:							
Insp	ector:	Area of v	vork	in	specte	ed:		
	ection Comments / Notes: (In Laid's to be provided, if applicable)	nclude commer	nt on a	any	alternati	ve solutions iden	tified, site observation statement	s, warranties
PASS If all works comply with the Consented documents and a Code Compliance Certificate can be issued please sign and date.				Signature			Signature	
	spection Result = FAIL then on the second three	omplete In	stru	ctic	on she	et ( <i>record nu</i>	umber here and on	
F = P = N/A	Fail = Non-complianc Pass = Compliance wit = Means that Bui relevant	h approved	d pla	ıns	& doc	umentation.		
Swimming Pools						Comments (r	reasons for decisions)	
1	Approved Consent documents or	site	Р	F	N/A			
2	Previous comments/ instructions		Р	F	N/A			
Read conditions of BC & PIM and determine if Resource Consent had been required & approved		Р	F	N/A				
4	Swimming Pool sited to plan. (disboundaries, survey pegs sited)	stance from	Р	F	N/A			
Loca	tion/ Immediate Pool Area		•	•	•			
6	Contains only items used for poo (BBQ, patio furniture, pool equipment		Р	F	N/A			
Fence	е							
8	1.2m high from outside ground le	vel.	Р	F	N/A	_		
9	1.2m clear ground to perimeter of permanent climbable objects within 1		Р	F	N/A			

N/A N/A

Fence	continued	Comments (reasons for decisions)							
121	Mesh size no greater than 10mm square for fences 1.2m high.	Р	F	N/A					
13	Mesh opening size no greater than 50mm for fences 1.8m high.	Р	F	N/A					
14	Picket fence type construction to have vertical gaps no greater than 100mm maximum	Р	F	N/A					
Gates									
15	Latches on outside to be no lower than 1.5mtrs from ground.	P	F	N/A					
16	Latches on inside to be no lower than 1.2mtrs from ground.	P	F	N/A					
17	To open outwards from pool area.	Р	F	N/A					
18	To self closing & self latching from 150mm from closed position.	P	F	N/A					
Doors / Windows in Building when part of Pool Fence									
19	All doors to have self closing and latching as per an outside gate.	Р	F	N/A					
20	Latch/handle to be a minimum of 1.5mtrs from floor on all types of doors.	P	F	N/A					
21	No hold open devices.	Р	F	N/A					
22	Windows < 1.2m above FFL have restriction stays limiting openings to 100mm	P	F	N/A					
Free Standing Pools									
23	Sides to be a minimum of 1.2mtrs from outside ground level.	P	F	N/A					
24	To Smooth vertical sides.	Ρ	F	N/A					
25	No climbing points.	Р	F	N/A					
26	Removable ladder (owners to be made aware of their responsibility.)	P	F	N/A					
Locka	able Lids								
27	Lockable lid to spa capable of taking 45kg weight	P	F	N/A					
28	Top of spa 760mm above ground or deck								
29	Deck is designed for spa weight (typically 6kpa)								
Water Supply And Drainage									
30	Backflow preventer fitted to pool water supply	Р	F	N/A					
31	Backwash discharge to council sewer	Р	F	N/A					
Documentation									
32	Form 6 completed and supplied	Р	F	N/A					
33	PS4 for construction if applicable (see BC conditions)	P	F	N/A					
34	Technical literature if applicable	Р	F	N/A					